FOR QUALITY & EXCELLENCE IN HIGHER EDUCATION
Accredited by NAAC

BANGALORE UNIVERSITY
DEPARTMENT OF CIVIL ENGINEERING

Phone Off: 080-22961935 / 1946
E-mail: centrans9@gmail.com

JNANA BHARATHI
BANGALORE - 560 056

BUB/CTE/2014-15/

DATE: 13-03-2015

1. TEST REPORT ON CEMENT CONCRETE CUBES:

Sub: Testing of Concrete Cubes (28 days Compressive Strength)
{Project*: Improvements to Roads Drains and Covering Slab at Muneshwara Layout in Ward No.10 (Doddabommasandra)}

Ref.: Letter No. Testing/BUB/2014-15, dated 12-03-2015

Sample supplied to lab by: Sri.Lakshinarayana.M, Contractor, Bangalore.

Report required for: Assistant Executive Engineer, Vidyaranayapura Sub-Division. BBMP, Bangalore.

RESULTS OF COMPRESSIVE STRENGTH ON CEMENT CONCRETE

CUBE SPECIMENS

Dimensions of Specimen : 150 X 150 X 150mm

Grade of Concrete* : M_{20}

TABLE 1.1 :

Sl No	Location/ Identification *	Date of Casting*	Date of Testing	Age in Days	C/S Area in Mm^2	Maximum Load in K.N	Compressive Strength (N/mm^2)	Avg. Value
1	001	12-02-15	12-03-15	28	22500	500	22.22	**22.81**
	002	"	"	"	"	510	22.66	
	003	"	"	"	"	530	23.55	
2	004	"	"	"	"	530	23.33	**23.70**
	005	"	"	"	"	535	23.77	
	006	"	"	"	"	540	24.00	

* As furnished by Client.
The Results relate only to the items tested.

G.R. HARISH
Professor
Department of Civil Engineering
Jnana Bharathi Campus
BANGALORE UNIVERSITY
Bangalore-560 056.

13/3/2015

Dr. MANJESH .L
ME(Civil Engg.) Ph.D., MISTE, MIRC
Associate Professor
Department of Civil Engineering
Bangalore University, Jnanabharathi Campus,
BANGALORE 560 056.
E-mail: manjeshl@yahoo.com